



تاريخ الطباعة : 2025-06-26
وقت الطباعة : AM 11:39
E-Service-WFS 2974

شهادة عدم ممانعة اعتماد منتج



106-PAC25007314

بيانات المنشأة

الإسم التجاري	: ام بالونجي
رقم قيد المنشأة	: 11-2991-01
رقم الرخصة التجارية	: 39073
البريد الإلكتروني	:
التصنيف	: Passive Fire Protection System
إسم المنتج	: Fire Proofing Materials

تفاصيل الشهادة

تم مراجعة الطلب المقدم واتضح بأنه لا مانع من اعتماد المنتج /المنتجات الموضحة في التقرير الفني المرفق بناء على اعتماده من قبل الهيئة المختبرية الموضحة في التقرير الفني المرفق.

ملاحظات

1. يجب على الشركة الالتزام والعمل بما جاء في اشتراطات قسم أنظمة السلامة التي تم الاطلاع والموافقة عليها من خلال الموقع.
2. يجب ان يقوم بتركيب هذا المنتج من قبل مهندسين وفنيين معتمدين من الإدارة العامة للدفاع المدني.
3. يجب ان يحمل المنتج العلامة التجارية للهيئة المختبرية المعتمدة والموضحة في التقرير الفني المرفق .

تاريخ انتهاء الشهادة : 2027-06-26

تاريخ اصدار الشهادة : 2025-06-26



تاريخ الطباعة : 2025-06-26
وقت الطباعة : AM 11:39
E-Service-WFS 2974

شهادة عدم ممانعة اعتماد منتج



106-PAC25007314

التقرير الفني

PRODUCT	Fire Proofing Materials			منتج
PRODUCT APPLICATION	Passive Fire Protection System			تصنيف المعدة
APPLICANT / P.O BOX	ام بالونجي			مقدم الطلب
MANUFACTURER / LOCATION	HEMPEL A/S / DENMARK			الشركة المصنعة / بلد الصنع
الوصف				الموديل
Hempafire Pro 315 is a one component, solvent-borne, physically drying intumescent coating for passive fire protection of structural steel against cellulosic fires. I/H Sections: Fire resistance rating refer to Applus certificate technical annex. Hollow Sections: Fire resistance rating refer to Applus certificate technical annex.				Hempafire Pro 315
3RD PARTY CERTIFICATE / APPROVAL	18/16292-1504 M1 and 18/16292-1504-1 M2	APF-1562	LGAI Technological Center S.A (APPLUS)	شهادة المختبرات المساندة (من هيئات معتمدة)
RECOMMENDATIONS				التوصيات
NOTES / STANDARDS				
Manufactured: PINTURAS HEMPEL, SAU / SPAIN HEMPEL PAINTS (Emirates) LCC / U.A.E. HEMPEL MANUFACTURING (MALAYSIA) SDN. BHD./ MALAYSIA. Refer to Applus certificate no. APF-1562 for the full details. Tested to standard EN 13381- 8 This product approval shall comply with the NFPA 5000 (and/or other related NFPA Codes / Standards), other acceptable International Codes / Standards, Local Regulations, Listing Instructions and/or Manufacturer's Published Instructions subject to the technical review and approval of the Authority Having Jurisdiction / Qatar Civil Defence.				

تاريخ انتهاء الشهادة : 2027-06-26

تاريخ اصدار الشهادة : 2025-06-26